

WEBEL TECHNOLOGY LIMITED

CORRIGENDUM – I

TENDER NO. WTL/HC/UPS/22-23/027 DATED 14.12.2022

| Sl. No. | Section No. | Page /Clause No. | Existing Clause Description | Clarification / Revised clause |
|---------|--|--|--|--|
| 1 | SECTION – I TECHNICAL SPECIFICATION WITH COMPLIANCE STATEMENT | Page No.: 26, Sl. No. 5 | Backup Time: 15 minutes on full load of 0.6 PF | Backup Time: 15 minutes on full load of 0.6 PF (BATTERY VAh: 12x7x1) |
| 2 | SECTION – D INSTRUCTION TO BIDDER | Page No.: 11, Sl. No. 15 (TIME SCHEDULE FOR DELIVERY & INSTALLATI ON) | Delivery & Installation Schedule: Delivery within 4 weeks after receiving of Work Order throughout West Bengal and within 6 weeks after receiving Work Order in Andaman Nicobar Island. Installation within 1 weeks after delivery for both West Bengal and Andaman Nicobar Island. | Delivery & Installation Schedule: Delivery within 6 weeks after receiving of Work Order throughout West Bengal and within 8 weeks after receiving Work Order in Andaman Nicobar Island. Installation within 2 weeks after delivery for both West Bengal and Andaman Nicobar Island. |